



**CACTUS STATE**

**Utility Operating Company**

A CSWR Managed Utility

## **IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

**Antelope Water Co. AZ0414001 Yuma County**

**Did Not Meet Treatment Requirements**

Our water system recently violated a drinking water standard. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor your water for turbidity (cloudiness). This tells us whether we are effectively filtering the water supply. Water samples for March 2026 showed 54 percent (17 out of 31 samples) of turbidity measurements were over 1 NTU (Turbidity units). The standard is that no more than 5 percent of samples may exceed 1 NTU (Turbidity units) per month.

### **What should I do?**

- You do not need to boil your water or take other actions. We do not know of any contamination, and none of our testing has shown disease-causing organisms in the drinking water.
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

### **What does this mean?**

This is not an emergency. If it had been, you would have been notified immediately. *Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.* These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

### **What is being done?**

Cactus State Utility Operating Company (UOC) is currently investigating the cause of elevated turbidity at this facility. As part of this effort, we are evaluating the performance and effectiveness of the existing filtration systems.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Cactus State Utility Operating Company for the Antelope Public Water System ID#: AZ0414001.

**Date Delivered: 4/27/2026**